


Key Considerations When Upgrading DNP3-Supported Communications

KS Hsu and Edward Lin
Moxa Product Managers

Introduction

Figuring out which solution fits a network's architecture best can be a daunting task for system integrators (SIs) when it comes to upgrading communications. Most often, SIs lack sufficient knowledge of protocols, complicating the task at hand even further. Not surprisingly, a frequently asked question by SIs is: "How can we simplify protocol conversion to ensure seamless operations in automation?" This question is particularly relevant for SIs who want to upgrade communications supported by Distributed Network Protocol (DNP3). Many SIs are further frustrated by the absence of sufficient built-in mechanisms to pinpoint where, as well as why, network communications break down, adding to the urgency of finding a reliable solution.

In the age of the Industrial Internet of Things (IIoT), protocol conversion is the key to connecting legacy and multivendor devices to networks. SIs often consider device servers, protocol gateways, or embedded computers for connecting their serial devices to Ethernet-based networks. But, due to their unfamiliarity with the variety of protocols currently in use, SIs are often at a loss to know which option is best suited for their network. In this white paper, we look at the various options available to upgrade serial-based DNP3 devices to Ethernet-based networks and expand on some of the key issues that need to be considered beforehand.



DNP3 Background and Benefits

Standardized in 1993, DNP3 is a protocol designed for remote telemetry; it is mainly used in power industry applications. In pre-DNP3 days, devices used by the power industry, such as RTUs (Remote Terminal Units) and IEDs (Intelligent Electronic Devices), could only use a serial interface to communicate. These devices connected with a local Human Machine Interface (HMI) for local monitoring and control, either via an RS-232 interface or via an RS-485 interface, and connected with the control center to give engineers the ability to remotely monitor and control the substation and power distribution status.

To transmit data over longer distances, engineers usually used a modem connected to the Public Switched Telephone Network (PTSN) for wired communication, or a radio for wireless

Released on September 14, 2016

© 2016 Moxa Inc. All rights reserved.

Moxa is a leading manufacturer of industrial networking, computing, and automation solutions. With over 25 years of industry experience, Moxa has connected more than 40 million devices worldwide and has a distribution and service network that reaches customers in more than 70 countries. Moxa delivers lasting business value by empowering industry with reliable networks and sincere service for automation systems. Information about Moxa's solutions is available at www.moxa.com.

How to contact Moxa

Tel: 1-714-528-6777

Fax: 1-714-528-6778

MOXA[®]
Reliable Networks ▲ Sincere Service

communication. The serial devices connected through the serial port on the dial-up modem or radio in the power station, which transmitted data to a modem or radio in the control center. The data was then transferred to the SCADA system in the control center. The transmission speed for this kind of setup was relatively slow, and the cost to transmit data via a modem was very high.

The introduction of DNP3 as a communication protocol brought a number of welcome changes. First, the cost of data transmissions dropped significantly. DNP3 is designed to transmit unsolicited responses from slave devices to a SCADA system, and consequently does not necessarily require a SCADA system to send frequent requests to field devices, ultimately leading to lower bandwidth consumption and reduced cost. Second, data would no longer be lost when modems unexpectedly disconnected. With DNP3, a buffer zone can serve as a temporary data storage location in case of an interruption. When communication resumes, the data stored in the buffer zone could easily be retrieved by the remote control center. Third, DNP3 supports time-stamped data records. Along with the time-synchronization function, events can be easily identified through a time sequence, as all control centers use the same time reference when data is sent back from edge devices.

In addition to substation and distributed automation applications, DNP3 is also widely used in the water processing, waste water, and oil and gas industries in North America, Australia, New Zealand, and some Asian countries.



The Easiest Way to Bring DNP3 Serial Devices to Ethernet-Based Networks

During the rapid development of network communication technology, many communication media have transitioned to Ethernet. On the master side of SCADA systems, an Ethernet interface, with integrated native Ethernet-based DNP3 drivers, is now commonplace. On the slave side, nothing much has changed. The existing DNP3 outstations (slaves) are still kept in operation because transforming such systems can be very expensive. For this reason, engineers are under constant pressure to find more budget-friendly solutions to enable serial-based DNP3 devices to connect with an Ethernet-based DNP3 master.

The first solution that comes to mind is device servers. With device servers, raw socket mode allows the physical conversion from a serial interface to an Ethernet interface for serial protocols. The Ethernet-based DNP3 protocol includes the standard TCP/IP header and DNP3 serial frame, which is also referred to as DNP3 over TCP/IP. Coincidentally, by using serial tunneling technology, device servers can add serial-based protocol frames into standard TCP/IP packets to handle protocol conversion between DNP3-serial packets and DNP3-over-TCP/IP packets.

When a system is upgraded—even though the system’s serial and legacy hardware are migrated to Ethernet-based networks—the old utility software is often still being used, making it necessary to enable the device servers’ virtual COM technology. The challenge, however, is that SIs may have to deal with different operating systems, which means the device servers need to support a different driver for each operating system. Even though this technology can support the basic requirements needed to execute serial-to-Ethernet tunneling, data that passes through device servers cannot be monitored, making it very difficult to identify the root cause of an abnormality during data transmissions.

Monitoring Protocol Conversion

Users who are looking for a more accurate means of monitoring protocol data transmissions to identify disruptions and abnormalities can use a protocol gateway. Protocol gateways not only convert serial-based DNP3 data packets into Ethernet-based packets, they also monitor and record these data packets through a tool built in to the web console. The tool also supports debugging and maintenance functions. In addition, users can view the raw data and its routing direction, considerably reducing the commissioning time and debugging process when the system is in operation.

When Cross Conversion is Needed

In the era of smart grids and the IIoT, a smart system, particularly in the power automation and process automation industries, needs to integrate a variety of networks. As more smart sensors and devices are added to a network, and more data is collected, it is highly likely that a large number of different protocols would need to be integrated. Modbus, the most widely used communication protocol in industrial applications, is perhaps the most common protocol that will need to be integrated into a DNP3-supported network.

Two methods can be used to integrate these different communication protocols. The first method employs embedded computers, enabling engineers to write and compile software for specific purposes to fulfill customization demands. Such solutions, though, require a comprehensive knowledge of protocols. The second method relies on protocol gateways, featuring plug-and-play integration of configured interfaces for Modbus and DNP3 protocols. With a protocol gateway, users only need to set up the corresponding Modbus commands, DNP3 commands, and the memory exchange configuration; data exchange between the different protocols can be easily implemented once the system is configured. The only drawback is that the protocol gateway solution is pre-configured, meaning it lacks flexibility when new functions need to be added.

Data Concentration

As automation systems become more integrated, SCADA systems need to monitor more and more devices and handle significantly larger amounts of data traffic. Normally, in a multi-layered architecture, a so-called data concentrator collects data from low-layer devices and sends it to the SCADA system at regular intervals. The advantage of using a data concentrator is that the SCADA system does not need to manage all of the devices in the field directly, since it only needs to communicate with the data concentrator. Funneling data through the data

concentrator dramatically reduces the frequency of communications, and ultimately decreases network traffic and the SCADA system's workload.

Embedded computers can easily play the role of data concentrator. Provided users have the programming ability, embedded computers can be used not only to collect, but also to analyze and filter data, allowing only processed data to be sent to the SCADA system.

Embedded computers, however, are not the best option when the requisite programming skill is lacking, or for systems that need to be implemented in a hurry. In these types of scenarios, a better option is to use protocol gateways that support agent mode, which actively and continuously retrieves data from connected devices. The updated data is stored in the gateway's internal memory, and the SCADA system can retrieve this data directly from the gateway's memory.

	Device Server	Protocol Gateway	Embedded Computer
DNP3 Serial-to-Ethernet	Serial tunneling	Conversion with inspection	Programming; requires protocol knowledge
DNP3-to-Modbus	N/A	Multiple integrated combinations	Programming; requires protocol knowledge
Data Concentration	N/A	Data packing	Programming; high data manageability

Table 1: A comparison of the technologies the different solutions rely on to facilitate the different protocol conversions.

Moxa offers a variety of products that meet the requirements for upgrading DNP3-supported applications, ensuring easier remote/telemetry communications. Moxa's NPort products easily convert serial-based DNP3 packets into Ethernet-based DNP3 packets, meeting various serial tunneling requirements. In addition, MGate 5109 gateways facilitate heterogeneous network conversion with a pre-configured user interface for DNP3 and Modbus. Furthermore, built-in diagnostic tools can be used to monitor the network status and raw data received by the protocols, easily fulfilling the requirements for debugging and system maintenance. UC-8100 embedded computers use the Cortex-A8 RISC processor for a useful computing platform, providing various communication interfaces, including serial, Ethernet, and cellular, for different development requirements.

To learn more, please visit: http://www.moxa.com/Event/Tech/2016/Modbus_DNP3/index.htm

Disclaimer

This document is provided for information purposes only, and the contents hereof are subject to change without notice. This document is not warranted to be error-free, nor subject to any other warranties or conditions, whether expressed orally or implied by law, including implied warranties and conditions of merchantability, or fitness for a particular purpose. We specifically disclaim any liability with respect to this document and no contractual obligations are formed either directly or indirectly by this document.

